

საქართველოს სტანდარტი

აკუსტიკა - გამოხსივებადი ხმის ენერჯის განსაზღვრა მილში
ვენტილატორითა და სხვა ჰაერის მოძრაობის მოწყობილობებით
(ისო 5136:2003)

საინფორმაციო ნაწილი. სრული ტექსტის სანახავად შეიძინეთ სტანდარტი.

საქართველოს სტანდარტებისა და მეტროლოგიის
ეროვნული სააგენტო
თბილისი

სსტ ენ ისო 5136:2009/2019

საინფორმაციო მონაცემები

1 შემუშავებულია საქართველოს სტანდარტების და მეტროლოგიის ეროვნული სააგენტოს სტანდარტების დეპარტამენტის მიერ

2 დამტკიცებულია და შემოღებულია სამოქმედოდ საქართველოს სტანდარტების და მეტროლოგიის ეროვნული სააგენტოს 2019 წლის 6 დეკემბრის № 98 განკარგულებით

3 მიღებულია გარეკანის თარგმნის მეთოდით სტანდარტიზაციის ევროპული კომიტეტის სტანდარტი ენ ისო 5136:2009 „აკუსტიკა - გამოხსივებადი ხმის ენერჯის განსაზღვრა მილში ვენტილატორითა და სხვა ჰაერის მოძრაობის მოწყობილობებით (ისო 5136:2003)“

4 პირველად

5 რეგისტრირებულია საქართველოს სტანდარტების და მეტროლოგიის ეროვნული სააგენტოს რეესტრში: 2019 წლის 6 დეკემბერი №268-1.3-016204

დაუშვებელია წინამდებარე სტანდარტის სრული ან ნაწილობრივი კვლავწარმოება, ტირაჟირება და გავრცელება სსიპ საქართველოს სტანდარტებისა და მეტროლოგიის ეროვნული სააგენტოს ნებართვის გარეშე

English Version

Acoustics - Determination of sound power radiated into a duct by fans and other air-moving devices - In-duct method (ISO 5136:2003)

Acoustique - Détermination de la puissance acoustique rayonnée dans un conduit par des ventilateurs et d'autres systèmes de ventilation - Méthode en conduit (ISO 5136:2003)

Akustik - Bestimmung der von Ventilatoren und anderen Strömungsmaschinen in Kanäle abgestrahlten Schalleistung - Kanalverfahren (ISO 5136:2003)

This European Standard was approved by CEN on 20 July 2009.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	3
Annex ZA (informative) Relationship between this European Standard and the Essential Requirements of EU Directive 98/37/EC	4
Annex ZB (informative) Relationship between this European Standard and the Essential Requirements of EU Directive 2006/42/EC	5

საინფორმაციო ნაწილი. სრული ტექსტის სახასიათოდ შეიძინეთ სტანდარტი.

Foreword

The text of ISO 5136:2003 has been prepared by Technical Committee ISO/TC 43 "Acoustics" of the International Organization for Standardization (ISO) and has been taken over as EN ISO 5136:2009 by Technical Committee CEN/TC 211 "Acoustics" the secretariat of which is held by DS.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by February 2010, and conflicting national standards shall be withdrawn at the latest by February 2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 5136:2003.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EC Directives.

For relationship with EC Directives, see informative Annexes ZA and ZB, which are integral parts of this document.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

Endorsement notice

The text of ISO 5136:2003 has been approved by CEN as a EN ISO 5136:2009 without any modification.

Annex ZA
(informative)

Relationship between this European Standard and the Essential Requirements of EU Directive 98/37/EC

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association to provide a means of conforming to Essential Requirements of the New Approach Directive 98/37/EC, amended by 98/79/EC on machinery.

Once this standard is cited in the Official Journal of the European Communities under that Directive and has been implemented as a national standard in at least one Member State, compliance with the normative clauses of this standard confers, within the limits of the scope of this standard, a presumption of conformity with the relevant Essential Requirements of that Directive and associated EFTA regulations.

WARNING - Other requirements and other EU Directives may be applicable to the product(s) falling within the scope of this standard.

საინფორმაციო ნაწილი. სრული ტექსტის სახასიათო შეიძლება სტანდარტი.

Annex ZB (informative)

Relationship between this European Standard and the Essential Requirements of EU Directive 2006/42/EC

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association to provide a means of conforming to Essential Requirements of the New Approach Directive 2006/42/EC on machinery.

Once this standard is cited in the Official Journal of the European Communities under that Directive and has been implemented as a national standard in at least one Member State, compliance with the normative clauses of this standard confers, within the limits of the scope of this standard, a presumption of conformity with the relevant Essential Requirements of that Directive and associated EFTA regulations.

WARNING — Other requirements and other EU Directives may be applicable to the product(s) falling within the scope of this standard.

INTERNATIONAL STANDARD

ISO 5136

Second edition
2003-04-01

Acoustics — Determination of sound power radiated into a duct by fans and other air-moving devices — In-duct method

*Acoustique — Détermination de la puissance acoustique rayonnée
dans un conduit par des ventilateurs et d'autres systèmes de
ventilation — Méthode en conduit*



Reference number
ISO 5136:2003(E)

© ISO 2003

საინფორმაციო ნაწილი. სრული ტექსტის სახსრად შეიძინეთ სტანდარტი.

PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

© ISO 2003

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
1.1 General	1
1.2 Types of sound source	1
2 Normative references	2
3 Terms, definitions and symbols	2
4 Uncertainty of the measurement method	7
5 Test facilities and instrumentation	8
5.1 General requirements	8
5.2 Duct specifications	9
5.3 Instrumentation	16
5.4 System calibration	19
6 Test arrangement	20
6.1 Sampling tube mounting	20
6.2 Microphone position	20
6.3 Operating condition control equipment	21
7 Test procedure	21
7.1 Operating conditions	21
7.2 Sound pressure level readings	21
7.3 Measurements with and without flow straightener on the outlet side	22
7.4 Inlet side measurements — Large fans: installation category D (according to ISO 5801:1997)	22
8 Calculations	23
8.1 Average sound pressure level	23
8.2 Sound power level	23
9 Information to be recorded	24
10 Information to be reported	24
Annex A (normative) Determination of the combined mean flow velocity and modal correction $C_{3,4}$	25
Annex B (normative) Determination of the signal-to-noise ratio of sound vs. turbulent pressure fluctuation in the test duct	31
Annex C (normative) Computational procedures for calculating the A-weighted sound power level from one-third-octave-band sound power levels	34
Annex D (informative) Example of calculation of $C_{3,4}$ for a given duct diameter and mean flow velocity	35
Annex E (informative) Guidelines for the design and construction of an anechoic termination	38
Annex F (informative) Evaluation of performance of anechoic terminations	47
Annex G (informative) Sampling tube information	50
Annex H (informative) Test method for small ducted fans	54
Annex I (informative) Test method for large ducted fans	58
Annex J (informative) Measurement of the swirl component	65
Bibliography	66

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 5136 was prepared by Technical Committee ISO/TC 43, *Acoustics*, Subcommittee SC 1, *Noise*.

This second edition cancels and replaces the first edition (ISO 5136:1990), which has been technically revised.

საინფორმაციო ნაწილი. სრული ტექსტის სანახავად შეიძინეთ სტანდარტი.

Introduction

This International Standard describes a procedure for the measurement of sound pressure levels in the inlet or outlet ducts of a fan and a method to use these sound pressure levels to calculate the sound power levels radiated by the fan to the duct system.

Annex A lists values of coefficients for the determination of the combined mean flow velocity and modal correction. Annex B specifies two procedures for the determination of the signal-to-noise ratio of sound versus turbulence. A computational procedure for the calculation of the A-weighted sound power level from one-third-octave band levels is given in Annex C. Annex D shows an example of the calculation of the combined mean flow velocity and modal correction.

The sound power radiated into a duct by a fan or other air-moving device depends to some extent on the type of duct, characterized by its acoustical impedance. For a measurement method, the test duct has, therefore, to be clearly specified. In this International Standard, the test duct is of circular cross-section and terminated anechoically. Details of typical anechoic terminations are given in Annex E. The sound power obtained under these special conditions is a representative value for actual applications, as the anechoic termination forms an impedance about midway between the higher and lower impedances found in practice. The sound power radiated in actual applications can, in theory, be estimated from data on air-moving devices and duct impedances. Since this information is at present incomplete, these effects are not usually considered in acoustical calculations.

In order to suppress the turbulent pressure fluctuations at the microphone, the use of a long cylindrical windscreen ("sampling tube") is preferred. The microphone, with the sampling tube, is mounted at a radial position such that the sound pressure is well related to the sound power by the plane wave formula to an acceptable extent, even in the frequency range in which higher-order acoustic modes are possible.

The uncertainty of measurement (see Clause 4) is given in terms of the standard deviation to be expected if the measurements were repeated in many different laboratories.

The procedures for measuring the operating conditions (performance measurements) are not specified in detail in this International Standard. The operating conditions are specified in ISO 5801.

This International Standard is one of a series specifying different methods for determining the sound power levels of fans and other air-moving devices.

In general, the sound powers radiated from a fan inlet or outlet into free space and into a duct are different because of the reflection of sound energy at the fan inlet or outlet plane when there is no connected duct. The in-duct method according to this International Standard is suitable for determining the sound power radiated into a duct by a fan inlet or outlet. The sound power radiated into free space by a fan inlet or outlet should be determined using the a reverberation room method (ISO 3741, ISO 3743), a free-field method (ISO 3744, ISO 3745, ISO 3746) or a sound intensity method (ISO 9614).