

საქართველოს სტანდარტი

სსკ: 13.040.35

სუფთა სათავსები და მათთან დაკავშირებული საკონტროლო არეები -
ნაწილი 21: ჰაერის ნაწილაკების ნიმუშის აღების ტექნიკები

სსტ ისო/ტრ 14644-21:2023/2023

საინფორმაციო მონაცემები

1 მიღებულია და დაშვებულია სამოქმედოდ: სსიპ-საქართველოს სტანდარტებისა და მეტროლოგიის ეროვნული სააგენტოს გენერალური დირექტორის 13/11/2023 წლის № 92 განკარგულებით

2 მიღებულია „თავფურცლის“ თარგმნის მეთოდით: სტანდარტიზაციის საერთაშორისო ორგანიზაციის (ისო) სტანდარტი ისო/ტრ 14644-21:2023 „სუფთა სათავსები და მათთან დაკავშირებული საკონტროლო არეები - ნაწილი 21: ჰაერის ნაწილაკების ნიმუშის აღების ტექნიკები“

3 პირველად

4 რეგისტრირებულია: სსიპ-საქართველოს სტანდარტებისა და მეტროლოგიის ეროვნული სააგენტოს რეესტრში: 13/11/2023 წლის №268-1.3-031647

წინამდებარე სტანდარტის ნებისმიერი ფორმით გავრცელება სააგენტოს ნებართვის გარეშე აკრძალულია

საინფორმაციო ნაწილი. სრული ტექსტის სანახავად შეიძინეთ სტანდარტი.

TECHNICAL REPORT

ISO/TR 14644-21

First edition
2023-08

Cleanrooms and associated controlled environments —

Part 21: Airborne particle sampling techniques

Salles propres et environnements maîtrisés apparentés —

Partie 21: Techniques de prélèvement des particules en suspension dans l'air



Reference number
ISO/TR 14644-21:2023(E)

© ISO 2023



COPYRIGHT PROTECTED DOCUMENT

© ISO 2023

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative documents	1
3 Terms and definitions	1
4 Determination of airborne particle concentration	2
4.1 General.....	2
4.2 Classification.....	3
4.3 Monitoring.....	4
4.4 Other LSAPC applications.....	4
5 Sampling airborne particles – things to consider	5
5.1 General.....	5
5.2 Instrument selection.....	5
5.2.1 General.....	5
5.2.2 Considered particle size selection.....	6
5.2.3 Required sample volume and sample flow rate.....	7
5.3 State of occupancy.....	7
5.3.1 General.....	7
5.4 Sample locations – points to consider.....	7
5.4.1 General.....	7
5.4.2 Sampling locations for classification.....	7
5.4.3 Sample locations for monitoring.....	9
5.5 Instrument measurement issues.....	10
5.5.1 General.....	10
5.5.2 Sampling errors.....	10
5.5.3 Sample measurement errors.....	13
5.5.4 Sample tubing issues.....	14
5.6 Decision tree.....	16
5.7 Examples of use of the decision tree.....	19
5.7.1 General.....	19
5.7.2 Example 1.....	19
5.7.3 Example 2.....	21
5.7.4 Example 3.....	23
6 Verifying a system	25
Bibliography	26

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by ISO/TC 209, *Cleanrooms and associated controlled environments*.

A list of all parts in the ISO 14644 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

საინფორმაციო ნაწილი. სრული ტექსტის სანახავად შეიძინეთ სტანდარტი.

Introduction

This document provides clarification on the application of sound airborne particle sampling techniques in support of ISO 14644-1:2015 for classification of cleanrooms and clean zones, and ISO 14644-2:2015 for airborne particle monitoring, to provide evidence of cleanroom performance related to air cleanliness by particle concentration. It provides information on how to gather appropriate, accurate and repeatable data, and how to interpret this information for the purpose of improving process protection. This also includes information on the choice of measurement methods and apparatus configuration, calibration, repeatability/reproducibility and the uncertainty associated with measurement. In short, what can be reasonably attained with the current technology.

This document addresses potential misinterpretation of the use of ISO 14644-1:2015, C.4.1.2 in informative Annex C, which suggests the use of limited tubing length for sampling macroparticles. The phrase in question has been applied beyond the context intended in ISO 14644-1, to other applications. This document also provides extra clarity on the use of the M Descriptor in ISO 14644-1:2015, Annex C, specifically in relation to consideration of $\geq 5,0 \mu\text{m}$ alongside ISO Class 5 (EU-PIC/S GMP Grade A and B at rest).

It provides information on the uncertainty associated with sampling particles $\geq 5,0 \mu\text{m}$ and macroparticles, and measures that can be taken to reduce that uncertainty.

It addresses the importance of understanding that:

- for classification, the quality of the sample is the most important factor;
- for monitoring, the quality of the data is the most important factor;
- direct sampling without tubing is preferred. However, sample tubing is sometimes necessary to get a representative sample at a significant or critical location;
- to reduce sampling loss in tubing, this tubing is as short and straight as possible;
- a sampling system is evaluated to assess the impact of any compromises in its set up.

An evaluation of existing sampling systems can deem them suitable for continued use even if the system is assessed as less than optimal.

The scientific basis for airborne particle counting, and the performance characteristics of airborne particle counters, particularly LSAPC, is amply documented in established technical publications (see Bibliography).

საინფორმაციო ნაწილი. სრული ტექსტის სანახავად შეიძინეთ სტანდარტი.